CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0981:107 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Greenheck Fan Corp., 400 Ross Ave., Schofield WI 54476-0410

Contact: *Marty Gissel (715) 355-6611

DESIGN: Models DFD-310, -350, -355; KFD-310, -350; FD-300, -310, -350, -355; SSDFD-350, -355;

SSKFD-350, SSFD-350, -355 curtain type fire dampers. Models may be followed by a five character suffix composed of numbers ranging from 0 to 9 and letters ranging from A to Z. Refer to listee's data sheet for detailed product description and operational considerations.

Models	Single Section		Multiple	e Section	Installation
	W	Н	W	Н	
FD-300	48"	48"	NA	NA	V
FD-310	48"	48"	NA	NA	V
FD-350	48"	48"	NA	NA	V
FD-350/-355	40"	40"	80"	40"	Н
DFD-310	36"	36"	NA	NA	V
DFD-350	36"	36"	NA	NA	V
DFD-350/-355	36"	36"	80"	40"	Н
KFD-310	36"	16"	NA	NA	V
KFD-350	36"	16"	NA	NA	V
KFD-350	36"	16"	80"	40"	Н
SSFD-350/-355	48"	48"	NA	NA	V
SSKFD-350	36"	16"	NA	NA	V
SSDFD-350/-355	36"	36"	NA	NA	V

RATING: 3 Hour

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as fire dampers for use as described under "Design".

*Rev. 05-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: MAY 8, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager